




# CORRUGATED ENT

## FLEXIBLE PVC CONDUIT

Size	Average Outer Diameter (OD)		Average Inner Diameter (ID)	
	Inches	mm	Inches	mm
1/2	0.840	21.34	0.602	15.29
3/4	1.050	26.67	0.804	20.42
1	1.315	33.40	1.029	26.14
1-1/4	1.660	42.16	1.360	34.55
1-1/2	1.900	48.26	1.590	40.39
2	2.375	60.32	2.047	51.99
2-1/2	2.875	73.02	2.469	62.70

Corrugated ENT Flexible Conduit, Models - 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2



- UL 1653 Listed Certification - E538283
- Lightweight
- Flexible
- Impact Resistant
- Concrete Tight
- Easy Installation
- Standard 100ft, 200ft lengths



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E538283  
**Report Reference** E538283-20231129  
**Issue Date** 2023-NOVEMBER-29

**Issued to:** 9486-2737 Québec inc. DBA PLC Piping  
CP 75066 Succ  
Cap-Rouge, QC, G1Y 3C6, CA

**This certificate confirms that representative samples of** ELECTRICAL NONMETALLIC TUBING  
See Addendum Page for Models

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 1653 – Electrical Nonmetallic Tubing  
**Additional Information:** See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

Certificate Number E538283  
Report Reference E538283-20231129  
Issue Date 2023-NOVEMBER-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

**Electrical nonmetallic tubing in trade sizes – Models, 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2.**

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Customer Service at <http://ul.com/aboutul/locations/>

