


Size	Outer Diameter (OD)		Minimum Average Inner Diameter (ID)		Minimum Thickness (T)	
	Average		Schedule 40		Schedule 40	
	Inches	mm	Inches	mm	Inches	mm
1/2	0.840 ± 0.004	21.34 ± 0.10	0.578	14.68	0.109	2.77
3/4	1.050 ± 0.004	26.67 ± 0.10	0.780	19.81	0.113	2.87
1	1.315 ± 0.005	33.40 ± 0.13	1.004	25.50	0.133	3.38
1-1/4	1.660 ± 0.005	42.16 ± 0.13	1.335	33.90	0.140	3.56
1-1/2	1.900 ± 0.006	48.26 ± 0.15	1.564	39.72	0.145	3.68
2	2.375 ± 0.006	60.32 ± 0.15	2.021	51.33	0.154	3.91
2-1/2	2.875 ± 0.007	73.02 ± 0.18	2.414	61.31	0.203	5.16
3	3.500 ± 0.008	88.90 ± 0.20	3.008	76.40	0.216	5.49
3-1/2	4.000 ± 0.008	101.60 ± 0.20	3.486	88.54	0.226	5.74
4	4.500 ± 0.009	114.30 ± 0.23	3.961	100.60	0.237	6.02
5	5.563 ± 0.010	141.30 ± 0.25	4.975	126.36	0.258	6.55
6	6.625 ± 0.011	168.28 ± 0.28	5.986	152.04	0.280	7.11
8*	8.625 ± 0.011	219.07 ± 0.28	7.853	199.47	0.322	8.18

Rigid PVC Conduit, Schedule 40, Models - 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 3-1/2, 4, 5, 6 (8* not UL Listed)



- UL 651 Listed Certification E533526
- Conforms to NEMA TC2 Standards
- Aboveground & Underground use
- Sunlight Resistant
- Impact Resistant
- Chemical & Corrosion Resistant
- Self Extinguishing
- Standard 10ft 20ft lengths





CERTIFICATE OF COMPLIANCE

Certificate Number E533526

Report Reference E533526-20230320

Issue Date 2023-MARCH-24

Issued to: 9486-2737 QUÉBEC INC. DBA PLC PIPING

CP 75066 Succ

Cap-Rouge, QC, G1Y 3C6 CANADA

This certificate confirms that RIGID NONMETALLIC PVC CONDUIT

representative samples of See Addenum Page for Models

Have been evaluated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 651 - Schedule 40, 80, Type EB and A Rigid PVC

Conduit and Fittings

Additional Information: See UL Product iQ® at https://ig.ulprospector.com for

additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



UL LLC





CERTIFICATE OF COMPLIANCE

Certificate Number

E533526

Report Reference **Issue Date** E533526-20230320 2023-MARCH-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.



Trademark and/or Tradename: "PLC Piping",

Rigid PVC Conduit, Schedule 40, Models - 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 3-1/2, 4, 5, 6

Rigid PVC Conduit, Schedule 40 with integral couplings, Models -1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 3-1/2, 4, 5, 6

Rigid PVC Conduit, Schedule 80, Models -1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 3-1/2, 4, 5, 6

Rigid PVC Conduit, Schedule 80 with integral couplings, Models -1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 3, 3-1/2, 4, 5, 6



Bruce Mahrenholz, Conformity Assessment Director

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, contact UL Customer Service at http://ul.com/aboutul/locations/

